

# ARLINGTON COUNTY, VIRGINIA

## PERMIT, INSPECTION AND PLAN REVIEW RECORDS

**PERMIT** 99146B0210      **STATUS:** EXPIRED      **TYPE:** RADD  
**APPLIED:** 08/20/1999      **APPROVED:** 10/12/1999      **ISSUED:** 10/12/1999  
**DESCRIPTION:** BLD A 2 LEVEL ADD. ABOVE GRND - RENEWAL OF PERMIT  
**LOCATION**      **ADDRESS:** 3018      16TH RD S  
**TENANT NAME:** ██████████

### REVIEW COMMENTS

ITEM	DATE	BY	ACTION	ACTION DESCRIPTION	COMMENTS
<b>100</b>	<b>CPHD:Building Department</b>				
	06/09/1999	JPR	AP	Approved	
<b>114</b>	<b>CPHD:Mechanical</b>				
	07/08/1999	CST	AP	Approved	
<b>300</b>	<b>CPHD:Zoning</b>				
	10/12/1999	cw	AP	Approved	2 sty addn maximum width 31 feet info transferred from old system
<b>400</b>	<b>DES:Engineering</b>				
	10/12/1999	wel	AP	Approved	

### INSPECTION COMMENTS

ITEM	DATE	BY	ACTION	ACTION DESCRIPTION	COMMENTS
<b>202 C: Footing</b>					
	09/26/2000	jpr	REJ	Rejected	need plans and removal of water and loose muck
	09/28/2000	egm	AP	Approved	ext. trench footing only
<b>208 C: Framing</b>					
	05/19/2000	ars	AP	Approved	duct to be cut into 2nd floor check on final mech located in crawl space need electric for this area need to have insulation -- firestopping finished while doing inspections
	10/19/2000	jpr	REJ	Rejected	
	10/26/2000	jpr	AP	Approved	
	05/11/2001	jpr	REJ	Rejected	need mech,elect

05/25/2001	jpr	REJ	Rejected	need elect.rough-in inspection and any other trade rough-ins
07/13/2001	ars	REJ	Rejected	framing to be completed so mech and electrical can finish work no idea of what system going in, svc or rear of building to be relocated so meter can be read, etc
05/06/2002	jpr	REJ	Rejected	problems are the same as last two inspections
05/17/2002	jpr	REJ	Rejected	no more free inspections if they do not pass inspection same problems persist no firestopping, no rough-in inspections,no approved plans
07/10/2002	jej	AP	Approved	

### 218 C: Final Building

08/16/2002	jpr	REJ	Rejected	no answer of door
08/23/2002	jpr	REJ	Rejected	need handrails, stair fix, all trades finished,not ready for final
09/14/2011	mcw	REJ	Rejected	need mech final, need smoke det in all bedrooms and hall outside bedroom
02/22/2012	jem	REJ	Rejected	need to repair elec wiring damage in attic(bare 14/2 conductors with squirrel damage and open ends)--need to complete /repair attic insulation need mech final see list

## EVENT LOG

DATE	DESCRIPTION	COMMENTS
09/26/2000	Request for inspection of item# 202	
09/28/2000	Request for inspection of item# 202	
10/19/2000	Request for inspection of item# 208	FRAMING FOR FIRST FLOOR INSPECTION
10/26/2000	Request for inspection of item# 208	PARTIAL
05/11/2001	Request for inspection of item# 208	
05/25/2001	Request for inspection of item# 208	
07/13/2001	Request for inspection of item# 208	
05/06/2002	Request for inspection of item# 208	
05/17/2002	Request for inspection of item# 208	
07/03/2002	Request for inspection of item# 208	
08/16/2002	Request for inspection of item# 218	
08/22/2002	Request for inspection of item# 218	
09/14/2011	Request for inspection of item# 218 Id:R000490056	
02/22/2012	Request for inspection of item# 218 Id:R000509689	

## LOCKS, HOLDS NOTICES

DATE	TYPE	USER	COMMENTS
09/07/2011	Comment	TCOOKE	Permit renewd for 6 month only