

EXPIRED PERMITS REPORT

PERMIT	APPLIED	EXPIRED	STATUS	TYPE	ADDRESS	DESCRIPTION	COST
4 Building Permit							
B1000155	01/27/2010	08/25/2010	EXPIRED	CTBO	900 N TAYLOR ST	CREATE OPENING IN WALL	\$395.49
	02/26/2010	AP			C: Wall Close-in		
R	C: Final Building			N			
B1300959	04/24/2013	10/30/2013	EXPIRED	CTBO	900 N TAYLOR ST	DAMAGE REPAIR PER SONNY ALLDER: **NO PLANS NEEDED**	\$275.59
						UNIT 1825 - WATER DAMAGE THRU OUT/FIRE SPRINKLER PIPE BREAK IN CLOSET ADJACENT TO STAIR TOWER(REPAIR PIPE & VERIFY NO DAMAGE TO 2 HR FIRE WALL)	
						UNIT 1411- WATER DAMAGE THRU OUT/FIRE SPRINKLER PIPE BR	
	04/25/2013	PA			C: Final Building	kitchen 2nd floor ok to occupy/ recieved service rep	
	05/02/2013	NOTE			C: Wall Close-in	need electrical inspection	
	05/03/2013	AP			C: Wall Close-in	-floors 2 and 3 repairs	
	05/03/2013	NOTE			C: Wall Close-in	Switched inspection with MLA.	
	05/03/2013	AP			C: Ceiling Close-in	-floors 2 and 3	
R	C: Final Building			N			
B1500017	01/05/2015	09/20/2015	EXPIRED	CTBO	900 N TAYLOR ST	GARAGE CONCRETE REPAIRS BY HYDRO DEMOLISHING SPECIAL INSPECTIONS REQUIRED	\$2,943.85
R	C: Final Building			N			
R	C:Special Inspect Final Letter			N			

PERMIT	APPLIED	EXPIRED	STATUS	TYPE	ADDRESS	DESCRIPTION	COST
<u>B1501483</u>	06/01/2015	09/01/2018	ACTIVE	CTBO	900 N TAYLOR ST	FACADE/ROOF REPAIRS	\$16,937.45
SPECIAL INSPECTIONS REQUIRED							
09/14/2017	NOTE	C: General Building			Construction in progress.		
R	C: Final Building		N				
R	C:Special Inspect Final Letter		N				
Summary for 'TITLE' = Building Permit (4 detail records)							TOTAL COUNT
							4
4		Electrical Permit					
<u>E1000199</u>	01/27/2010	03/30/2011	EXPIRED	COM	900 N TAYLOR ST	1 FIXTURE	\$104.14
02/26/2010	AP	C: Concealment					
09/30/2010	CA	C: Concealment			IVRS - AP canceled		
10/01/2010	REJ	C: Concealment			contact phone disconnected, no door access.		
R	C: Final Electrical		N				
<u>E1101808</u>	07/08/2011	01/04/2012	APPLIED	COM	900 N TAYLOR ST		\$0.00
R	C: Final Electrical		N				

PERMIT	APPLIED	EXPIRED	STATUS	TYPE	ADDRESS	DESCRIPTION	COST
E1301390	05/28/2013	01/27/2014	EXPIRED	COM	900 N TAYLOR ST	REPLACE 1 CIRCUIT FOR HOT TUB	\$104.14
	07/31/2013	AP			C: Final Electrical		
R		C: Bonding		N			
R		C: Concealment		N			
R		C: Ditch Concealment		N			
R		C: Door Locking Systems		N			
R		C: General Electrical		N			
R		C: Generator		N			
R		C: Preventative Maintenance		N			
R		C: Service		N			
R		C: Site Lighting		N			
R		C: Slab		N			
R		C: Systems Furniture Elec		N			
R		C: Temporary Power		N			
E1501156	05/05/2015	03/31/2017	EXPIRED	COM	900 N TAYLOR ST	3 CIRCUITS , 55 FIXTURES	\$237.06
R		C: Final Electrical		N			

Summary for 'TITLE' = Electrical Permit (4 detail records)

TOTAL COUNT 4

2	Plumbing Permit
----------	------------------------

PERMIT	APPLIED	EXPIRED	STATUS	TYPE	ADDRESS	DESCRIPTION	COST
P1301449	05/28/2013	11/24/2013	EXPIRED	COM	900 N TAYLOR ST	1 RUB REPLACEMENT	\$104.14
07/31/2013	REJ	C: Final Plumbing			no temp valve and vac breaker		
R	C: Additional Time			N			
R	C: Cross Connection			N			
R	C: Final Plumbing			N			
R	C: Fire Main Water Service			N			
R	C: Gas Pressure Test			N			
R	C: General Plumbing			N			
R	C: Groundwork			N			
R	C: Periodic Cross Conn - Apt			N			
R	C: Periodic Cross Conn - Comm			N			
R	C: Plumbing C of O			N			
R	C: Rough Plumbing			N			
R	C: Sewer			N			
R	C: Sewer Cap-off Plumbing			N			
R	C: Water Service			N			
P1501467	05/19/2015	11/15/2015	EXPIRED	COM	900 N TAYLOR ST	1 BATHROOM GROUP, 1 DISHWASHER, 1 ICE MAKER, 1 LAVATORY, 1 SINK, 1 WATER CLOSET	\$266.36
R	C: Final Plumbing			N			

Summary for 'TITLE' = Plumbing Permit (2 detail records)

TOTAL COUNT	2
Grand Total	10

ARLINGTON COUNTY, VIRGINIA

PERMIT, INSPECTION AND PLAN REVIEW RECORDS

PERMIT B1000155 **STATUS:** EXPIRED **TYPE:** CTBO
APPLIED: 01/27/2010 **APPROVED:** 01/27/2010 **ISSUED:** 01/27/2010
DESCRIPTION: CREATE OPENING IN WALL
LOCATION **ADDRESS:** 900 N TAYLOR ST
TENANT NAME: ██████████

REVIEW COMMENTS

ITEM	DATE	BY	ACTION	ACTION DESCRIPTION	COMMENTS
100	CPHD:Building Department				
	01/27/2010	pmb	AP	Approved	
110	CPHD:Plumbing				
	01/27/2010	sms	N/A	No review required	1. No plumbing work is shown. If plumbing waste or vent stacks are encountered in area of proposed opening and if the location of these stacks is to be changed or offset plumbing plans must be submitted
112	CPHD:Electrical				
	01/27/2010	gms	N/A	No review required	
114	CPHD:Mechanical				
	01/27/2010	sms	N/A	No review required	No mechanical work shown.
116	CPHD:Fire Prevention				
	01/27/2010	pmb	N/A	No review required	
300	CPHD:Zoning				
	01/27/2010	JWH	AP	Approved	INTERIOR ALTERATIONS TO KITCHEN IN CONDO UNIT ON 18TH FLOOR OF 21 STORY BUILDING. INSTALL PASSTHROUGH WINDOW FROM KITCHEN TO DINING ROOM.
400	DES:Engineering				
	01/27/2010	RE	AP	Approved	KITCHEN RENOV. NO PLUMBING WORK.
410	DES:Water/Sewer Engineering				
	01/27/2010	RE	AP	Approved	KITCHEN RENOV. NO PLUMBING WORK.

INSPECTION COMMENTS

ITEM DATE BY ACTION ACTION DESCRIPTION COMMENTS

210 C: Wall Close-in

02/26/2010

cdv

AP

Approved

EVENT LOG

DATE DESCRIPTION COMMENTS

01/27/2010 B / P Sets RECVD 1st Revw

01/27/2010 B / P Sets RELESD Const

02/26/2010 Request for inspection of item# 210 Id:R000423700

LOCKS, HOLDS NOTICES

DATE TYPE USER COMMENTS

01/27/2010 Notice MWINSTON AFFIDAVIT ATTACHED TO APPLICATION

PERMIT B1300959

STATUS: EXPIRED

TYPE: CTBO

APPLIED:

04/24/2013

APPROVED:

04/24/2013

ISSUED:

04/24/2013

DESCRIPTION: DAMAGE REPAIR PER SONNY ALLDER: **NO PLANS NEEDED**

UNIT 1825 - WATER DAMAGE THRU OUT/FIRE SPRINKLER PIPE BREAK IN CLOSET ADJACENT TO STAIR TOWER(REPAIR PIPE & VERIFY NO DAMAGE TO 2 HR FIRE WALL)

UNIT 1411- WATER DAMAGE THRU OUT/FIRE SPRINKLER PIPE BREAK MIDDLE OF UNIT (REPAIR PIPE & ELECTRICAL OPEN J-BOXES IN CEILING IN CEILING CONCEALED)

2ND & 3RD FLOOR- SHUT OFF POWER, OPEN IN CEILINGS & WALLS, INSPECTION BEFORE CLOSE UP/WATER DAMAGE THRU OUT

NOTE: LIST IS NOT COMPLETE UNTIL AREAS ARE OPENED UP & INSPECTED

LOCATION

ADDRESS: 900 N TAYLOR ST

TENANT NAME: SUNRISE SENIOR LIVING

REVIEW COMMENTS

ITEM	DATE	BY	ACTION	ACTION DESCRIPTION	COMMENTS
100	CPHD:Building Department				
	04/24/2013	mkm	N/A	No review required	
110	CPHD:Plumbing				
	04/24/2013	mkm	N/A	No review required	
112	CPHD:Electrical				
	04/24/2013	mkm	N/A	No review required	
114	CPHD:Mechanical				
	04/24/2013	mkm	N/A	No review required	
116	CPHD:Fire Prevention				
	04/24/2013	mkm	N/A	No review required	
300	CPHD:Zoning				
	04/24/2013	mkm	N/A	No review required	
410	DES:Water/Sewer Engineering				
	04/24/2013	mkm	N/A	No review required	

INSPECTION COMMENTS

<i>ITEM</i>	<i>DATE</i>	<i>BY</i>	<i>ACTION</i>	<i>ACTION DESCRIPTION</i>	<i>COMMENTS</i>
210 C: Wall Close-in					
	05/02/2013	mla	NOTE	NOTATION	need electrical inspection
	05/03/2013	mla	AP	Approved	-floors 2 and 3 repairs -unit 1411 -stair tower
	05/03/2013	mvc	NOTE	NOTATION	Switched inspection with MLA.
211 C: Ceiling Close-in					
	05/03/2013	mla	AP	Approved	-floors 2 and 3 -unit 1411 Note: need fire sprinkler inspection for repairs before close up
218 C: Final Building					
	04/25/2013	mla	PA	Partial Approval	kitchen 2nd floor ok to occupy/ recieved service reports that state hood ansal system testrd by Simplex

EVENT LOG

<i>DATE</i>	<i>DESCRIPTION</i>	<i>COMMENTS</i>
05/02/2013	554616* Request for insp.# 210 Id:R000566497	Scheduled by IVR.
05/03/2013	554737* Request for insp.# 210 Id:R000566717	Scheduled by IVR.

LOCKS, HOLDS NOTICES

<i>DATE</i>	<i>TYPE</i>	<i>USER</i>	<i>COMMENTS</i>
04/24/2013	Notice	MMYLES	DAMAGE REPORT OFFLINKED

PERMIT B1500017

STATUS: EXPIRED

TYPE: CTBO

APPLIED:

01/05/2015

APPROVED:

03/24/2015

ISSUED:

03/24/2015

DESCRIPTION: GARAGE CONCRETE REPAIRS BY HYDRO DEMOLISHING
SPECIAL INSPECTIONS REQUIRED

LOCATION

ADDRESS: 900 N TAYLOR ST

TENANT NAME: GARAGE

REVIEW COMMENTS

ITEM	DATE	BY	ACTION	ACTION DESCRIPTION	COMMENTS
100	CPHD:Building Department				
	01/13/2015	tjc	REJ	Rejected	Submit a complete set of signed and sealed repair drawings. Indicate repair locations and approximate repair size as well as if it is full or partial repair. Include repair details on the plans. Clearly designate the Virginia Construction Code year used for the design on the plan. All projects are reviewed under the requirements outlined in the Virginia Uniform Statewide Building Code. A written response letter must accompany plan revisions. Please contact the Plan Examiner for any clarification of the comments. Reviewer: Mary Sniezek, 703.228.3862
110	03/11/2015	tjc	AP	Approved	
	CPHD:Plumbing				
	01/08/2015	brg	REJ	Rejected	COMMERCIAL PLAN REVIEW All projects are reviewed under the requirements outlined in the Virginia Uniform Statewide Building Code. A written response letter must accompany plan revisions. Please contact the Plans Examiner for any clarification of the comments. Permit #:B1500017Applicable Code:VUSBC 2012 Edition Project Name :Plans Examiner:Bernie Gill Address:900 N. Taylor St.Discipline: Plumbing Review Date:1-8-15Phone Number:703-228-3873 Review #:1stFax Number:703-228-7046 Revision Date:NAEmail:bgill@arlingtonva.us SheetCommentsCode Reference 1S-1Shows 4 new drains being installed at the ramp and note #4 indicates that they are to connect to the storm system. Please show the new drain and pipe sizes. Sheet A1.1 has the sewage ejector highlighted. Please clarify. The storm drains cannot connect to the sanitary system. Please show the storm piping connection.2012 VPC 1101.3 2A1.6I am unsure what is indicated on this sheet. Is this a 2" water connection? No water piping is in this location. If so what is the water connection for? This information will help to determine the type of backflow device needed. Further comments may accompany resubmission.
03/11/2015	tjc	AP	Approved	for brg - misplaced entry	

112	CPHD:Electrical				
	01/14/2015	sgn	N/A	No review required	Garage concrete repair
	03/09/2015	sgn	N/A	No review required	
114	CPHD:Mechanical				
	01/08/2015	fc	N/A	No review required	
	03/09/2015	fc	N/A	No review required	
116	CPHD:Fire Prevention				
	01/13/2015	tjc	N/A	No review required	garage repair
	03/11/2015	tjc	N/A	No review required	
220	Special Inspection Required				
	01/08/2015	MVS	REJ	Rejected	Submit Statement of Special Inspections. a. Download form here: http://building.arlingtonva.us/project/special-inspections/ b. Complete the cover sheet. Note: Statement will not be approved without SIER and GC information. c. The Schedule (p.2-9) shall be completed by the SER. In the last column write "SER", "SIER", "TAER" or "N/A" to indicate who will be responsible for each required test and inspection. The SIER and SER shall also initial in these columns. In the section labeled "Other Inspection", identify any required tests/inspections not listed. d. All parties identified on the cover sheet must sign and date final sheets (p.10&11). E Submit Statement of Special Inspections. Submitted document shall contain original signatures. Reviewer: Mary Sniezek, 703.228.3862
	03/11/2015	MVS	AP	Approved	
240	Structural Review				
	01/08/2015	MVS	REJ	Rejected	Submit Full set of signed and sealed repair drawings. Indicate repair locations and approximate repair size as well as if it full or partial repair. Include repair details. Submit applicable building codes, concrete strength, design loads, etc. All projects are reviewed under the requirements outlined in the Virginia Uniform Statewide Building Code. A written response letter must accompany plan revisions. Please contact the Plan Examiner for any clarification of the comments. Reviewer: Mary Sniezek, 703.228.3862
	03/11/2015	MVS	AP	Approved	
300	CPHD:Zoning				
	01/06/2015	DAM	NOTE	NOTATION	This plan was distributed to Melissa Goutos 703-228-7564 first review comments will be posted within 30 days.
	02/04/2015	MG	AP	Approved	GARAGE CONCRETE REPAIRS, 9,000 SF TOTAL. ANY RESTRIPING TO MATCH THE ORIGINAL APPROVED ZONING PLANS ON FILE FOR SP #249.
	03/06/2015	dnh	NOTE	NOTATION	This revision was distributed to Melissa Goutos 703-228-7564. Review should be complete within 10 days.
	03/10/2015	DAM	NOTE	NOTATION	This plan was distributed to Melissa Goutos 703-228-7564 first review comments will be posted within 10 days.
	03/17/2015	MG	REJ	Rejected	INCOMPLETE SUBMISSION. NO REVISIONS MARKED ON THE ZONING SET OF PLANS WITH DATE STAMP. UNABLE TO COMPLETE ZONING REVIEW.

	03/23/2015	DAM	NOTE	NOTATION	This plan was distributed to Melissa Goutos 703-228-7564 first review comments will be posted within 10 days.
	03/23/2015	MG	AP	Approved	REVISED 3/23/2015 FOR ZONING SET BUT 3/04/2015 IN ISD. GARAGE CONCRETE REPAIRS ON P1 & P2 EAST & WEST, 9,000 SF TOTAL. RESTRIPIING TO MATCH THE ORIGINAL APPROVED ZONING PLANS ON FILE FOR SP #249.
400	DES:Engineering				
	03/24/2015	SJB	AP	Approved	INT GARAGE REPAIRS. NO PLUMBING. APPROVED
410	DES:Water/Sewer Engineering				
	03/24/2015	SJB	AP	Approved	INT GARAGE REPAIRS. NO PLUMBING. APPROVED

INSPECTION COMMENTS

EVENT LOG

<i>DATE</i>	<i>DESCRIPTION</i>	<i>COMMENTS</i>
01/05/2015	B / P Sets RECVD 1st Reww	
03/04/2015	B / P Sets OUT for Revision	REJ B&O TO ELIZABETH HERRITY TO REVISE
03/04/2015	SSI PACKAGE TO MARY SNIEZEK	
03/04/2015	B / P Sets BACK Review	REVISED B&O TO LIBRARY FOR REVIEW
03/24/2015	B,O SET TO MS. ELISABETH TO ZONING AND DES	B,O SET TO MS. ELISABETH TO ZONING AND DES
03/24/2015	B / P Sets RELESD Const	

LOCKS, HOLDS NOTICES

PERMIT B1501483

STATUS: ACTIVE

TYPE: CTBO

APPLIED: 06/01/2015

APPROVED:

01/20/2016

ISSUED:

01/20/2016

DESCRIPTION: FACADE/ROOF REPAIRS

SPECIAL INSPECTIONS REQUIRED

LOCATION

ADDRESS: 900 N TAYLOR ST

TENANT NAME: THE JEFFERSON

REVIEW COMMENTS

ITEM	DATE	BY	ACTION	ACTION DESCRIPTION	COMMENTS
100	CPHD:Building Department				
	06/04/2015	lp	AP	Approved	Facade (masonry) and roof/deck repairs
	01/13/2016	lp	N/A	No review required	SSI Only
110	CPHD:Plumbing				
	06/04/2015	lp	N/A	No review required	
	01/13/2016	lp	N/A	No review required	SSI Only
112	CPHD:Electrical				
	06/04/2015	lp	N/A	No review required	
	01/13/2016	lp	N/A	No review required	SSI Only
114	CPHD:Mechanical				
	06/04/2015	lp	N/A	No review required	
	01/13/2016	lp	N/A	No review required	SSI Only
116	CPHD:Fire Prevention				
	06/03/2015	jdm	N/A	No review required	
	01/05/2016	jdm	N/A	No review required	
	01/13/2016	lp	N/A	No review required	
220	Special Inspection Required				

	06/08/2015	mrm	REJ	Rejected	1. Submit Statement of Special Inspections. a. Download form here: http://building.arlingtonva.us/project/special-inspections/ b. Complete the cover sheet. Note: Statement will be rejected if SIER or GC information is incomplete. c. The Schedule (p.2-9) shall be completed by the SER. In the last column write "SER", "SIER", "TAER" or "N/A" to indicate who will be responsible for each required test and inspection. In the section labeled "Other Inspection", identify any required tests/inspections not listed. Please also include BRICK VENEER, ROOFING, EXPANSION JOINT AND SEALANT WORK in the scope of special inspections. d. All parties identified on the cover sheet must sign and date final sheets (p.10&11) and sign as required on p.3 - 9. e. Submit one original hard-copy and retain additional copies for any required resubmittals. 2. Submit resumes for special inspection personnel. 3. Submit documentation demonstrating laboratory accreditation. Reviewer: Matt Marrion, 703.228.7638
	01/06/2016	HC	REJ	Rejected	1) On page 1 of the submitted SSI form, the information for testing agency engineer and general contractor shall be filled in. On page 10, testing agency shall sign on the SSI form. 2) to get approval, we will need the original of SSI form to be re-submitted. Either pick up the submitted SSI form to provide the request information or download a new SSI form from county website.
240	01/14/2016	HC	AP	Approved	
	Structural Review				
	06/08/2015	mrm	REJ	Rejected	1. Drawings shall be signed and sealed by structural engineer licensed in Virginia. 2. Provide concrete repair details. 3. Specify structural design loads for roof and veneer. Reviewer: Matt Marrion 703.228.7638
300	01/06/2016	HC	AP	Approved	Revised sheets, dated 1/4/2016.
	CPHD:Zoning				
	06/01/2015	DAM	NOTE	NOTATION	This plan was distributed to Melissa Goutos 703-228-7564. First review comments should be posted in approximately 30 days or as soon as possible thereafter.
	06/30/2015	MG	AP	Approved	FACADE AND PLAZA REPAIRS. ALL MATERIALS TO MATCH THE EXISTING.
	01/04/2016	dnh	AP1	Approved as Noted	ISD Revisions dated 1/4/16. Previous note regarding materials applies.
400	01/20/2016	DMH	NOTE	NOTATION	REVISIONS ON 1/11/16 WERE TO SUBMIT THE SSI FORM ONLY. PLANS DID NOT CHANGE
	DES:Engineering				
	01/20/2016	SJB	AP	Approved	COMMERCIAL INT ALT. NO PLUMBING. APPROVED
410	DES:Water/Sewer Engineering				
	01/20/2016	SJB	AP	Approved	COMMERCIAL INT ALT. NO PLUMBING. APPROVED

INSPECTION COMMENTS

<i>ITEM</i>	<i>DATE</i>	<i>BY</i>	<i>ACTION</i>	<i>ACTION DESCRIPTION</i>	<i>COMMENTS</i>
219 C: General Building					
	09/14/2017	dj	NOTE	NOTATION	Construction in progress.
98 Special Inspections					
	09/20/2017	VAC	NOTE	NOTATION	Project brought to my attention by Damian. Hank reviewed and approved plans. Emailed all parties to add me to distribution list and for field reports.

EVENT LOG

<i>DATE</i>	<i>DESCRIPTION</i>	<i>COMMENTS</i>
06/01/2015	B / P Sets RECVD 1st Reww	
01/04/2016	B / P Sets OUT for Revision	
01/04/2016	B / P Sets BACK Review	
01/11/2016	B / P Sets OUT for Revision	
01/11/2016	B / P Sets BACK Review	SSI FORM ONLY. PLANS NOT CHANGED
01/20/2016	B / P Sets RELESD Const	
09/14/2017	Request for inspection of item# 219 Id:R000791645	

LOCKS, HOLDS NOTICES

<i>DATE</i>	<i>TYPE</i>	<i>USER</i>	<i>COMMENTS</i>
03/30/2017	Comment	MMYLES	6 MONTH EXTENSION GRANTED
04/04/2017	Notice	GHANCOCK	Applicant would like to extend permit until 06/18/2018. He has been advised to send a letter to the Building Official for grant this request.

PERMIT E1000199 **STATUS:** EXPIRED **TYPE:** COM
APPLIED: 01/27/2010 **APPROVED:** 01/27/2010 **ISSUED:** 01/27/2010
DESCRIPTION: 1 FIXTURE
LOCATION **ADDRESS:** 900 N TAYLOR ST
TENANT NAME: ██████████

REVIEW COMMENTS

<i>ITEM</i>	<i>DATE</i>	<i>BY</i>	<i>ACTION</i>	<i>ACTION DESCRIPTION</i>	<i>COMMENTS</i>
100	CPHD:Building Department				
	01/27/2010	MAW	AP	Approved	
112	CPHD:Electrical				
	01/27/2010	MAW	AP	Approved	

INSPECTION COMMENTS

<i>ITEM</i>	<i>DATE</i>	<i>BY</i>	<i>ACTION</i>	<i>ACTION DESCRIPTION</i>	<i>COMMENTS</i>
803 C: Concealment					
	02/26/2010	rmb	AP	Approved	
	10/01/2010	sgn	REJ	Rejected	contact phone disconnected, no door access.

EVENT LOG

<i>DATE</i>	<i>DESCRIPTION</i>	<i>COMMENTS</i>
02/26/2010	Request for inspection of item# 803 Id:R000423701	
10/01/2010	461822* Request for insp.# 803 Id:R000450033	Scheduled by IVR.

LOCKS, HOLDS NOTICES

PERMIT E1101808

STATUS: APPLIED

TYPE: COM

APPLIED: 07/08/2011

APPROVED:

ISSUED:

DESCRIPTION:

LOCATION

ADDRESS: 900 N TAYLOR ST

TENANT NAME:

REVIEW COMMENTS

INSPECTION COMMENTS

EVENT LOG

LOCKS, HOLDS NOTICES

PERMIT E1301390

STATUS: EXPIRED

TYPE: COM

APPLIED: 05/28/2013

APPROVED: 05/28/2013

ISSUED: 05/28/2013

DESCRIPTION: REPLACE 1 CIRCUIT FOR HOT TUB

LOCATION

ADDRESS: 900 N TAYLOR ST

TENANT NAME: [REDACTED]

REVIEW COMMENTS

<i>ITEM</i>	<i>DATE</i>	<i>BY</i>	<i>ACTION</i>	<i>ACTION DESCRIPTION</i>	<i>COMMENTS</i>
112	CPHD:Electrical				
	05/28/2013	DI	AP	Approved	

INSPECTION COMMENTS

<i>ITEM</i>	<i>DATE</i>	<i>BY</i>	<i>ACTION</i>	<i>ACTION DESCRIPTION</i>	<i>COMMENTS</i>
812 C: Final Electrical					
	07/31/2013	alh	AP	Approved	

EVENT LOG

<i>DATE</i>	<i>DESCRIPTION</i>	<i>COMMENTS</i>
07/31/2013	Request for inspection of item# 812 Id:R000578620	

LOCKS, HOLDS NOTICES

PERMIT E1501156

STATUS: EXPIRED

TYPE: COM

APPLIED: 05/05/2015

APPROVED: 05/05/2015

ISSUED: 05/05/2015

DESCRIPTION: 3 CIRCUITS , 55 FIXTURES

LOCATION

ADDRESS: 900 N TAYLOR ST

TENANT NAME: ██████████

REVIEW COMMENTS

<i>ITEM</i>	<i>DATE</i>	<i>BY</i>	<i>ACTION</i>	<i>ACTION DESCRIPTION</i>	<i>COMMENTS</i>
100	CPHD:Building Department				
	05/05/2015	SMG	AP	Approved	
112	CPHD:Electrical				
	05/05/2015	SMG	AP	Approved	

INSPECTION COMMENTS

EVENT LOG

LOCKS, HOLDS NOTICES

PERMIT P1301449 **STATUS:** EXPIRED **TYPE:** COM
APPLIED: 05/28/2013 **APPROVED:** 05/28/2013 **ISSUED:** 05/28/2013
DESCRIPTION: 1 RUB REPLACEMENT
LOCATION **ADDRESS:** 900 N TAYLOR ST
TENANT NAME: ████████

REVIEW COMMENTS

<i>ITEM</i>	<i>DATE</i>	<i>BY</i>	<i>ACTION</i>	<i>ACTION DESCRIPTION</i>	<i>COMMENTS</i>
100	CPHD:Building Department				
	05/28/2013	DI	AP	Approved	
400	DES:Engineering				
	05/28/2013	jna	AP	Approved	
410	DES:Water/Sewer Engineering				
	05/28/2013	jna	AP	Approved	

INSPECTION COMMENTS

<i>ITEM</i>	<i>DATE</i>	<i>BY</i>	<i>ACTION</i>	<i>ACTION DESCRIPTION</i>	<i>COMMENTS</i>
409 C: Final Plumbing					
	07/31/2013	jhl	REJ	Rejected	no temp valve and vac breaker

EVENT LOG

<i>DATE</i>	<i>DESCRIPTION</i>	<i>COMMENTS</i>
07/31/2013	Request for inspection of item# 409 Id:R000578619	

LOCKS, HOLDS NOTICES

PERMIT P1501467

STATUS: EXPIRED

TYPE: COM

APPLIED: 05/19/2015

APPROVED: 05/19/2015

ISSUED: 05/19/2015

DESCRIPTION: 1 BATHROOM GROUP, 1 DISHWASHER, 1 ICE MAKER, 1 LAVATORY, 1 SINK, 1 WATER CLOSET

LOCATION

ADDRESS: 900 N TAYLOR ST

TENANT NAME: SPTMRT PROPERTIES TRUST %SUNRI

REVIEW COMMENTS

<i>ITEM</i>	<i>DATE</i>	<i>BY</i>	<i>ACTION</i>	<i>ACTION DESCRIPTION</i>	<i>COMMENTS</i>
<i>100</i>	CPHD:Building Department				
	05/19/2015	PJ	AP	Approved	
<i>110</i>	CPHD:Plumbing				
	05/19/2015	PJ	AP	Approved	
<i>400</i>	DES:Engineering				
	05/19/2015	JLM	AP	Approved	INT ALT NO NEW DFU'S
<i>410</i>	DES:Water/Sewer Engineering				
	05/19/2015	JLM	AP	Approved	INT ALT NO NEW DFU'S

INSPECTION COMMENTS

EVENT LOG

LOCKS, HOLDS NOTICES
